

Part 3

Local Amendments to International Plumbing Code

15A-4-301 General provision.

The amendments in this part are adopted as amendments to the IPC to be applicable to specified jurisdiction.

Enacted by Chapter 14, 2011 General Session

15A-4-303 Amendments to IPC applicable to South Jordan.

The following amendments are adopted as amendments to the IPC for South Jordan:

- (1) IPC, Section 312.10.2, is deleted and replaced with the following: "312.10.2 Testing. Reduced pressure principle backflow preventer assemblies, double check-valve assemblies, pressure vacuum breaker assemblies, reduced pressure detector fire protection backflow prevention assemblies, double check detector fire protection backflow prevention assemblies, hose connection backflow preventers, and spill-proof vacuum breakers shall be tested at the time of installation, immediately after repairs or relocation and at least annually. The testing procedure shall be performed in accordance with one of the following standards: ASSE 5013, ASSE 5015, ASSE 5020, ASSE 5047, ASSE 5048, ASSE 5052, ASSE 5056, CSA-B64.10, or CSA-B64.10.1. Assemblies, other than the reduced pressure principle assembly, protecting lawn irrigation systems that fail the annual test shall be replaced with a reduced pressure principle assembly."
- (2) IPC, Section 608.16.5, is deleted and replaced with the following: "608.16.5 Connections to lawn irrigation systems. The potable water supply to lawn irrigation systems shall be protected against backflow by a reduced pressure principle backflow preventer."

Enacted by Chapter 14, 2011 General Session